

Temp Set @ 26°F

				Highest	Cabinet	Cabinet			Upper	Upper		
		24 hr		Amb	Temp	Temp	Cabinet	Δ from	Temp	Temp	Upper	Δ from
	AMP HRS	Amps	Amps / Hr	Temp	High	Low	Temp Avg	Setting	High	Low	Temp Avg	Setting
30-Sep	0			83	34	28	31.1	5.1	52	46	48.7	22.7
1-Oct	12.80	12.80	0.53	95	35	30	32.4	6.4	50	43	45.3	19.3
2-Oct	29.47	16.67	0.69	93	36	30	33.0	7	50	42	45.7	19.7
3-Oct	48.78	19.31	0.77	81	36	28	32.3	6.3	48	44	46.2	20.2
Total 74 Hr Use		51.17										
Use Per hour		0.69										
Avg Use Per Day		16.60										